

AUTOMATIC FIRE SPRINKLER SYSTEM STANDARDS

Development Standard #4

- I.** Fire sprinkler plans are required to be checked and approved by this department prior to installation. Any system must be in compliance with NFPA Standard #13 or #13D or #13R as applicable.
 - A.** Any work being undertaken by the applicant (including applicant's agents or contractors) shall be in accordance with the following:
 - 1. The fire department shall determine the location of any fire department connection (FDC) that may be required.
 - 2. The fire department shall have on file a set of approved plans prior to any work being done.
 - 3. A set of approved plans, stamped and dated by the fire department shall be kept at the work site and available upon request.
 - 4. Water systems shall be installed exactly as the approved plans dictate. No changes or modifications to these plans shall take place without prior fire department approval.
 - 5. No work shall be covered or otherwise rendered inaccessible or unviewable prior to inspection by a fire department representative.
 - 6. A minimum of 48 hours notice shall be given to the fire department by the applicant prior to scheduling an inspection.